



BÖWE
PASSAT

Installation Instructions

P 564



Safety hints

Each person who is in charge of installing, commissioning, operating, servicing or repairing of the textile drycleaning machine, must have read and understood the operating and installation manual. We explicitly refer to the observance of the respective laws and regulations of the countries in question.

The drycleaning machine was built according to the latest state of engineering and may only be assembled, installed, operated, served and repaired by persons familiar with the machine and informed about possible dangers. The relevant safety regulations as well as other safety and industrial medicine rules are to be strictly obeyed.

Installation and commissioning

When installing the drycleaning machine the enclosed installation instructions should be obeyed. A sufficient room ventilation system must be available. In rooms that require pressure colling, it must be ascertained that the drycleaning machine can be turned on only, when the ventilation system is in operation.

The machine should not be installed in rooms with danger of explosion.

The first start-up is carried out by the service department of the BÖWE-PASSAT Organization.

Authorized use

This textile drycleaning machine is exclusively designed for operation with Perchloroethylene (Tetrachlorethen C_2Cl_4). The direct handling with these solvents should be reduced to absolutely necessary work, whereby safety gloves and -goggles should be worn.

Inflammable, poisonous or radioactive textiles should not be treated.

It is relevant that the prescribed BÖWE-PASSAT operating, service and maintenance regulations are maintained.

Unauthorized changes and alterations of the equipment exclude liability of the manufacturer from resulting damages.

Operation and Maintenance

Operation and maintenance of the BÖWE-textile drycleaning machine is reserved for qualified and trained specialist staff. Take system into operation only after all safety devices are installed and in function. During operation and maintenance all safety regulations are to be obeyed.

Check machine daily for operational safety before turning on (for leakages) and control feed readings. Dispose of lint and distillation residue according to the operating manual.

Do not carry out any maintenance work while machine is running. Please pay attention to the recommended quality of solvents, lubricants, and additives!

Repairs

Repairs may only be carried out by skilled workers with tools and protection of labour that is destined for it. Avoid solvent emissions.

When carrying out repairs and cleaning work always turn off main switch and protect equipment from being turned on unauthorized. (Sign: Don't turn on - Repair Work!). When work is being done on the electrical system - always remove the master fuse.

Only use original fuses when exchanging defective ones. Work carried out on pneumatic control parts has to be done without pressure. Check compressed air indicator for pressure. Repairs on the refrigerating aggregate may only be done by a refrigeration engineer specially trained for this.

All spare parts used must comply with the technical standards set by the manufacturer.

Setting machine out of operation and disassembly

Setting machine out of operation and disassembly is only reserved for qualified and trained specialists, with tools and protection of labour that is destined for it.

- Setting machine out of operation and disassembly solvent must be completely drained off from the machine including pipes and armatures. Residues which can produce work shop or environmental handicaps must be removed.
- Machine pipes and electric wires for providing and waste disposal must be separated from network and must be guard against incompetent turn on.
- Cooling solvent from refrigeration unit must be removed by trained service people.

Dear customer,

It gives us great pleasure to supply you with your 5th generation **BÖWE-PASSAT** machines. In designing and building it we have attached great importance to quality. It is up to the latest level of research and technology, particularly concerning environmental protection.

Please do not put this operating manual aside unread!

This manual contains important information on operational details of your drycleaning machine.

If specified measurements and installation information are disregarded, we cannot meet the warranty obligations contained in our General Terms of Delivery.

Measurements and other values are as at printing date.

We reserve the right to make technical changes without prior notice in the interest of further development or required constructional modifications.

Reproduction - including excerpts - is only permitted with prior written approval and acknowledgements.

B Ö W E - P A S S A T

Reinigungs- und Wäschereitechnik GmbH

D-8900 Augsburg, Postfach 10 13 80, Haunstetter Str. 112

Telefon 0821 /57020, Telex 536480 boe d, Telefax 0821/5702-351

West-Germany

BÖWE-PASSAT P 564

Contents	Page
<u>1. General information</u>	4
<u>2. Machine rear</u>	5
<u>3. Transportation</u>	
3.1 Entry	6
<u>4. Foundation</u>	
4.1 Foundation measurements	7
4.2 Anchoring	8
4.3 Noise or vibration insulation	8
<u>5. Solvent safety trough</u>	9
5.1 First installation	10
5.2 Cementing in the stone bolts	10
5.3 Safety expanding anchor	10
5.4 Threaded rods (bored through floor)	11
<u>6. Installation</u>	
6.1 Surrounding conditions	13
6.1.1 Regulations	13
6.1.2 Temperature	13
6.1.3 Machine surroundings	13
6.2 Place of installation	14
6.2.1 Required space	14
6.2.2 Machine dimensions	14
6.3 Floor load	14
6.3.1 Dimensions	15
6.3.2 Anchoring modes	15
6.4 Machine installation	15

BÖWE-PASSAT P 564

Contents

Page

7. Connection

7.1	Machine dimensions specification	16
7.2	Machine connections specification	17
7.3	Piping	18
7.3.1	Steam	18
7.3.2	Condensate	18
7.3.3	Cooling water supply	18
7.3.4	Cooling water drain	20
7.3.5	Processing water	21
7.3.6	Compressed air	21
7.3.7	Electric connection	21
7.3.8	Actuation of room ventilation	22

1. General information

Technical literature

We make reference to the publications and leaflets by the trade and professional associations as well as research institutes.

Laws and regulations

All regulations concerning the industry, particularly with regard to proper handling of halogen hydrocarbons, have to be met absolutely in order to avoid health risks and environmental damage.

In any case please observe applicable laws and regulations in your country.

Applied National Standards and Regulations:

- VBG 66 - Safety Regulations for Drycleaning Equipment
- VBG 20 - Safety Regulations for Refrigeration Equipment
- Heatpumps and Refrigeration Plants
- VDE 0100 - Requirements for High Tension up to 1000 V
- Pressure Vessel Regulations
- CFC - Halon Prohibition Decree

The following applies to the Federal Republic of Germany:

2nd Federal Emission Protection Law (2.BImSchV)
 Water conservation Law (WHG § 19)
 Disposal law
 Technical rules for dangerous substances (TRGS 402)
 VDI guide lines
 DIN Standards
 VDE regulations

Repair work

Please consult the BÖWE-PASSAT customer service organization for all maintenance and repair work as well as operating safety aspects of this high-quality drycleaning machine. If necessary, the BÖWE-PASSAT customer service organization will use original spare parts.


Safety

Safety devices may not be bypassed, switched off or otherwise be made inoperative. In case of repair work please observe applicable industrial safety rules.

Disposal of still residues, processing water, lint etc. must be carried out properly.

In case of repair work please observe applicable industrial safety rules.

2. Machine rear




- | | | | |
|----|--------------------------|----|--------------------------------|
| 1 | Fan | 11 | Pump |
| 2 | Recovery section | 12 | Post separator |
| 3 | Air heater | 13 | Water separator |
| 4 | Air cooler | 14 | CONSORBA |
| 5 | Refrigeration unit | 15 | Condenser |
| 6 | Cage drive | 16 | Filter drive |
| 7 | Cage housing with cage | 17 | Filter |
| 8 | Dosing unit | 18 | Still |
| 9 | Tanks | 19 | Still heating |
| 10 | Lint filter /button trap | 20 | Anti-foaming agent dosing pump |

3. Transportation

For proper transportation, installation and connection it is recommended to consult the appropriate experts.

For unloading transportation, machine entry and installation it is necessary to use suitable tools and devices such as a crane, forklift, elevating truck, bottle lift, ropes, winch, crowbars, rollers, wooden blocks, wedges.

Transportation equipment for entering the machine can be leased from BÖWE-PASSAT.



3.1 Entry

Normally the machine is transported and entered in upright position in a wooden crate or box.

Packing dimensions (box dim.)	Machine	
Length	mm	3400
Width	mm	2050
Height (fan and condenser pipe dismantled)	mm	2500

There are alternatives if the entry is too small:

Normal dimensions after unpacking (machine dim.)


Length	mm	3210
Width	mm	1890
Height	mm	2300

After disassembly work (loading door, pump, button trap, still rake-out door, piping)

Width	mm	1590
Height	mm	2300

4. Foundation

4.1 Foundation measurements



Reinforced concrete: for normal floors at least 300 mm deep

A

Hole for stone bolt or expanding anchor depending on make

B

Room floor - concrete slab

C

(If necessary) ceiling breakthrough for supply lines

with occasional trough 850 mm

without occasional trough 1600 mm


E

Distance from P 564 to nearest machine (outside edge of machine panelling)




F

4. Foundation

Installation over ceilings



Installation over ceilings with sound insulation



H

Ceiling borehole 20 mm \varnothing) for through-bolts, length depending on thickness of ceiling.
Support if necessary.

K

Machine on reinforced concrete slab 100 - 200 mm and pressed foundation cork 12 - 15 mm with 1 - 3 kp/cm².
Below the ceiling pressed cork and steel plate 10 mm.
Ceiling borehole 30 mm diameter (if necessary PVC hose inset).

4.2 Anchoring

Correct anchoring is very important for low-noise, fault-free operation. For installation on foundation it is preferable to use stone bolts!



Seating must be horizontal and level. Do not place machine directly on tiles, felt, bituminous coatings, rubber or cork.

With uneven concrete floors it is necessary to level the machine or trough frame with wedges and fill the spaces with cement.

4.3 Noise or vibration insulation

For special vibration insulation special foundations, dampers etc. can be used in collaboration with building and insulation specialists.

5. Solvent safety trough



5. Solvent safety trough

The machine is delivered with a two-part trough:


Measurement:	machine trough:	length 3215 mm, width 2110 mm
	occasional trough:	length 3215 mm, width 715 mm

5.1 First installation of trough

Trough anchoring:

There are 3 alternative anchoring methods:

- Stone bolts for cementing in
(use preferably; length 250 mm)
- Safety expanding anchors
for inserting in bored holes
- Threaded rods
for through-holes in case of installation over ceilings



Thread for all anchoring methods: M 16

5.2 Cemented-in stone bolts

Work sequences:

Separate trough and frame, insert stone bolts into frame holes with plain washers, spring washers and nuts.

Stone bolt (X) must project 65 mm over concrete (please see page 9 for details).

Level the frame (watch the front). If floor is uneven, level frame with wedges and fill spaces with cement.

Fill anchoring holes with quick-taking cement.

After cementation tighten nuts evenly. Remove stone bolt nut (X).

Unscrew brass seal bonnet from trough, do not damage the gasket. Put trough into frame.

Tighten nut and washer of the stone bolt (X).

5.3 Safety expanding anchors

Work sequences:

Separate frame from trough.

Install frame at intended location.

Caution: Please watch the front (see drawing on page 9).

5. Solvent safety trough

Use frame as drilling template.

Pilot-drill with rock drill 16 mm.

Minimum drilling depth 130 mm.

Remove frame.

Using the template drill 130 mm deep with 25 mm rock drill.

Remove nuts and washers of expanding anchors.

The upper plug bushes must be shorted.

Put anchors into drilled holes.

Caution: Long expanding anchor into bore (X) screw with seal bonnet.

Put the frame on and level. If floor is uneven, level with wedges and fill spaces with cement.

Tighten anchor nuts evenly.

Put trough into frame.

Tighten nut and washer of screw with seal bonnet (X).

Caution: In tightened condition the threaded bolt may not project more than a maximum of 5 mm over the nut (grind off if longer).

Safety expanding anchors can be obtained from BÖWE-PASSAT.

Safety expanding anchors are included in the machine trough (SN 195051)

2 long SN 149466

6 short SN 149469

5.4 Threaded rods (bored-through ceiling)

Work sequences:

Separate frame from trough.

Install frame in intended location.

Caution: Please watch front (see drawing on page 9).

Use frame as drilling template.

Pilot-drill with rock drill 16 mm.

Remove frame.

In case of normal installation over a ceiling drill 20 mm deep with rock drill (see foundation drawing).

In case of vibration-insulated installation over a ceiling (see foundation drawing) drill 30 mm deep with rock drill.

5. Solvent safety trough

The frame must be completely level on the floor.
If not, level with wedges and fill spaces with cement.

With both floor installations (normal and vibration-insulated),
the screw with seal bonnet (X) must freely project 65 mm.

6. Installation

6.1 Surrounding conditions

6.1.1 Regulations

Applicable regulations for room ventilation and size, odour and noise emissions, accident prevention etc. must be met.

The control box contains contacts to control the room air (see page 22).

Noise level at a distance of 1 meter from the machine and 1.6 meters over the ground: 74 dB (A)

Higher noise level depends on distance from walls or ceiling. In this case local arrangements are necessary.

6.1.2 Temperature

Machine should not be exposed to direct sunlight. Adequate air supply is to be ensured due to heat exchange (heat build-up!) Room temperature should not drop below 1 °C owing to the risk of water in the system freezing, and not exceed 40 °C in continuous operation owing to increased solvent consumption.

Heat radiation:

without CONSORBA	27800 kJ
with CONSORBA	32200 kJ

6.1.3 Structural surroundings

Partitions, screens, intermediate ceilings and similar near the machine are to be fitted in such a way that they do not hinder operation and are easily and quickly removed for maintenance and repair.

NOTE!

Do not operate appliances with open flames, e.g. gas-fired flatwork ironers, tumblers, in the same room, because they can be damaged by noxious, corrosive gases in the event of solvent decomposition.


Please ensure that no air from the machine can escape into a possibly existing heating plant room.

6. Installation

6.2 Place of installation

6.2.1 Required space

Front and rear of the machine should be accessible for operation, maintenance and repair. Without the machine trough, there have to be a minimum distance between machine back and wall of 1000 mm.



6.2.2 Machine dimensions

Length (with trough)	mm	3215
Width	mm	1890
Height without trough	mm	2630
Height with trough	mm	2753

6.3 Floor load

The place of installation must conform to the floor load which is composed of:

- static load = machine weight + max. solvent filling and
- dynamic load = centrifugal cage force with normally distributed, extraction-damp garments.

The force created during extraction must also be taken into account (floor, supporting walls etc.). Resonances are not permissible.

Please consult building specialists.

6. Installation

6.3.1 Dimensions

with CONSORBA

Length	mm	3150
Width	mm	1150
Floor surface	m ²	3.62
Weight without solvent	kg	3050
Weight with solvent (stat. load)	kg	4350
Centrifugal cage force (dyn. load)	N	16600
Floor load (stat. + dyn. load)		
- Standard drive	N/m ²	15400




Regarding the foundation work please consult building experts. They will take machine-related as well as local particulars into account and find the best solution.

Please use a load distributor if the permissible floor load is inadequate. We also recommend to install a solvent safety trough (a must in Germany). Please see page 9.

6.3.2 Anchoring methods

- For installation over ceilings
Through-bolts (threaded rod)
with washers and nuts M 16
- For installation on foundation
Stone bolts for cementing in recessed
or opened holes.
- or
- Heavy-load plugs with threaded rod
- or
- Safety expanding anchors for inserting
in bored holes.

We will not be liable for any damage caused by disregard
for our recommendations and information.



M 16


6.4 Machine installation

Work sequences:

Using rollers and other tools bring machine 10 mm over the trough. It is preferable to push the machine into the trough from the narrow side. If the machine has to be pushed on from the front, BÖWE-PASSAT supports SN 139516 are available. For mounting instructions please see the label on the supports. Screw machine to frame by means of hexagon screws M 16 (included in delivery). Retighten foundation screw nut with seal bonnet (X). Put on copper gasket according to drawing. Screw on seal bonnet and tighten. Insert gratings.


7. Connection

7.1 Machine dimensions specification



7. Connection

7.2 Machine connections specification



We reserve the right to change measurements!

Pos.	Medium	NW mm	Zoll inch	- X - mm	- Y - mm
1	Steam/Airheater	15	1/2	2190	2280
2	Sewage	20	3/4	2025	190
3	Cooling water	20	3/4	1880	120
4	Condensate running off CONSORBA + airheater	15	1/2	1540	220
5	Elec. connection (bottom of control-box)			1570	520
6	Condensate running off/still	25	1	200	50
7	Sewage	20	3/4	75	1207
8	Steam /Still	25	1	150	1200
9	Steam CONSORBA	15	1/2	1430	1600
10	Compressed air	8	1/4	1310	1650
11	SPRAYMATIC	12	3/8	60	125

7. Connection

7.3 Piping

Connect the supply and drain pipes (supplied by customer) in accordance with the installation details. Steam, compressed air and water must receive stop valves. Water connection must be according to DIN 1988. To avoid sound conduction through solids, an intermediate piece - made of flexible metal hose - can be connected and the pipe supports insulated.


7.3.1 Steam

Installation and connection should be insulated
Avoid the use of asbestos!

Operating pressure 4 - 5 bar saturated steam

At a pre-pressure of more than 5 bar a reducing valve with pressure gauge must be installed and set so that the admissible max. Temp. of 150 °C (please measure!) is not exceeded. (Danger of solvent decomposition and machine damage!)

Steam requirement (steam generator size) with CONSORBA 1.65 kg/min.



7.3.2 Condensate

Install insulated condensation line with a slope, away from the machine.

In case of an ascending slope check valve and drainage must be at the lowest point.

Important: Condensate counter-pressure must be at least 1.5 bar below the steam inlet pressure.

7.3.3 Cooling water supply

Fit the line to the machine without reduction of cross section and if possible without bends. The heat balance of the machine is optimally set to 12 °C cooling water inlet temperature and a uniform pressure of 2 - 4 bar.

7. Connection

For safety reasons a water flowback stop and venting device should be installed.

With a pressure drop in the cooling water supply or higher cooling water temperatures (e.g. re-chilling operation), the supply line must be at least one nominal size larger. Inlet temperatures should not exceed 22 °C as otherwise stains would be caused on the garments, solvent consumption would increase and the drying time would be longer.

Water pressure must be adapted to the higher inlet temperature up to double the max. requirement.

With re-chilling the correct installation is especially important. Among other things, the following must be taken into account: cooler performance, switch-over to public city water supply, low temperature storage, pump size, cooling water valve by-pass. Pump pressure 4 - 6 bar.

The cooling water valve for the still must be removed.


The cooling water valve for the refrigeration unit must be changed and replaced by a new one with one nominal width larger.

The cooling water inlet must be connected with the city-water supply.

Cooling water peak demand 2 - 3 bar / 12 °C:

with CONSORBA

22 l/min



Data for temperatures up to 22 °C:

Min. nominal width	NW	25 / 1"
Pump throughput	m ³ /h	0.6
Pump pressure	bar	4 - 6

Heat to be eliminated:


without CONSORBA	kJ/h	62500
with CONSORBA	kJ/h	68100

7. Connection


Installation examples for cooling water supply

Connection for city water supply

Cooling water drains
must be separate.



Connection with water recirculation (refrigeration unit or cooling tower)



When supply and drain lines are fitted with hand valves, both valves must be opened before starting the machine, so that cooling is ensured and the sensor in the condensate drain line of the still responds in case of cooling water shortage.

7.3.4 Cooling water drain

Cooling water leaving the machine can be passed to the drains, re-used or re-chilled as it flows in closed circuit within the machine and has no contact with solvent.

Cooling water re-use is preferable.

7. Connection

7.3.5 Processing water

The processing water collecting container must be drained every day. Purify by means of processing water purification system.

7.3.6 Compressed air

Air pressure should be at least 6.0 bar. The machine is equipped with a compressed air reducing valve, pressure gauge and compressed air water separator.

7.3.7 Electric connection

Note mains voltage (data-plate). Make connections L1/L2/L3, establish neutral and protective conductor with corresponding cross-section and fusing. Pass cable through existing PG union into the control box and connect at terminal.

P 564 without CONSORBA

P 564 da

	Operating load kW	12.5
230 V	Nominal current A	47.5
	Fuse A	63
400 V	Nominal current A	27.4
	Fuse A	50

P 564 with CONSORBA

P 564 da

	Operating load kW	13.6
230 V	Nominal current A	53
	Fuse A	80
400 V	Nominal current A	30.6
	Fuse A	50

7. Connection

7.3.8 Actuation of room ventilation

Regulations permit to couple the machine's automatic controls to a room ventilation fan. The machine cannot be started before room ventilation has been switched on.

Room air intake Inlet 71 (in 71)
A1-x7/8b
A1-x7/8z

The contacts are connected with the fan controls.

Room ventilation fan

